



METER SIZE	BY-PASS LINE SIZE	BY-PASS MATERIAL
3"	2" MIN.	COPPER
4"	2" MIN.	COPPER
6"	4"	DI
8"	6"	DI

VAULTS SHALL BE PRE-APPROVED PRIOR TO INSTALLATION BY CITY PERSONNEL

NOTES:

1. ALL JOINTS SHALL BE RESTRAINED FROM THE MAIN LINE TEE TO PROVIDE FOR METER REMOVAL WHILE USING BY-PASS LINE.
2. PRIOR TO METER INSTALLATION, GATE VALVES SHALL BE ALIGNED & SPACED W/RIGID SPOOL. CONTACT CITY WATER DEPT. FOR DISTANCE BETWEEN METER GATE VALVES PRIOR TO INSTALLATION. (835-2662)



# STANDARD 3" & LARGER METER INSTALLATION

DATE: December 2016

DETAIL NO.

W22